



East County Fire and Rescue

600 NE 267th Avenue Camas, WA 98607

(360) 834-4908 (phone)

(360) 835-8920 (fax)

www.ecfr.us



Resolution #356-11052024

A resolution providing for disposal of equipment deemed to be surplus to the reasonably foreseeable needs of East County Fire and Rescue.

WHEREAS, the equipment shown in Attachment A, belonging to East County Fire & Rescue is obsolete and no longer needed by the district.

NOW, THEREFORE, BE IT RESOLVED by the Board of Commissioners of East County Fire & Rescue as follows:

1. Based upon the findings and recommendations of the Fire Chief, this equipment is surplus to the foreseeable needs of the district.
2. Disposal of this equipment will benefit the district.
3. The fire chief is authorized dispose of this equipment in a manner that will be to the best advantage of East County Fire and Rescue.

ADOPTED at a Regular Meeting of the Board of Commissioners for East County Fire and Rescue November 05, 2024, with the following Commissioners being present and voting:


 Joshua Seeds, Chairperson


 Martha Martin, Commissioner



 Brendan Addis, Commissioner

DocuSigned by:

 B71A6CF232AD43D...
 Michael Taggart, Vice Chair


 Steve Hornmaster, Commissioner

Attest


 Debbie Macias, District Secretary
 Ed Hartin, Chief (Alternate)





East County Fire and Rescue

600 NE 267th Avenue Camas, WA 98607

(360) 834-4908 (phone)

(360) 835-8920 (fax)

www.ecfr.us



Property Salvage Report

Tag Number	Description of Asset	Serial Number	Status of Asset: Choose One				Comments
			Lost	Stolen	Sold	Recycle/Scrap	
n/a	2-1/2in x 50ft hose	80217	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	oos hole in jacket
n/a	2-1/2in x 50ft hose	286	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1-3/4in x 50ft hose	16-145	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	oos hole in jacket
n/a	1in x 100ft hose	ID# rubbed off jacket	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	oos hole in jacket
n/a	2-1/2in x 50ft hose	299	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	2-1/2in x 50ft hose	236	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1in x 100ft hose	000-10	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	2-1/2in x 25ft hose	260	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1in x 100ft hose	9142	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	5in x 25ft hose	spliced 100ft section no ID	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	5in x 25ft hose	spliced 100ft section No ID	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1-1/2 x 100ft hose	003A	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1in x 100ft hose	00015	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1-1/2 x 100 ft hose	008A	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1-1/2 x 100ft hose	0010	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1-1/2 x 100ft hose	spliced 100ft section no ID	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1-1/2in x 100ft hose	002	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test
n/a	1-1/2in x 100ft hose	006A	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	failed hose test

